

Za evakuacijska vrata v bolnici se mora upoštevati:

- standard SIST EN 1125 > 200 postelji
- standard SIST EN 179 < 200 postelji

Activity	Position of door	Panic exit device (EN 1125)	Emergency exit device (EN 179)
		Examples of solutions: P1-P6 PP1 – PP6*	Examples of solutions: N1 – N3 NP1 – NP3*
Hotel, except restaurant etc	To stairway		X
< 200 beds	From stairway to external air		X
	To stairway		X
Hotel, except restaurant etc	To stairway		X
> 200 beds	From stairway to external air	X	
	To stairway		X
Health care premises, < 200 beds	From stairway to external air		X
	To stairway		X
Health care premises, > 200 beds	From stairway to external air	X	

Lep pozdrav,

Aleš Glavnik

mag. Aleš Glavnik, udiš
direktor
PIN d.o.o.
Nad črto 55
SI-2351 Kamnica
<http://www.pin-nb.si>
GSM: ++386 41 645 450

